

RCLLC inventory of on site transformers

bldg/floor	details	jpeg #	notes
9/200	square D powerzone transformers class: AA-H serial # 36626 . Electrical consultant identified initially as dry type.	1 2 3 4 5 6	undergoing further research by RCLLC electrical consultant.
9/300	one jeffereson electric dry type transformer cat # 423-7234-000 one square D energy star transformer cat#75T3HEE. Dry type confirmed by sticker.	7 8 9	2 new transformers installed by a tullys contractor. Located on the mezzanine level in tullys packaging
8/300	square D dry type(according to electrical contractor)transformer cat# 75T3HEE style: 34349-17212-064 type:SO UL listing :127H. Dry type confirmed by sticker	10 11	Located in tullys packaging area
6/500	FPT dry type transformer cat# T4T150. Dry type confirmed by sticker	12 13 14	located in the tullys
6/300	square D cat#30T3HCU style: 33349-17212-057 type: SO UL listing: 127H dry type confirmed by research	15 16 17 18	located in the tullys storage area
9/200	Not a transformer. A reactor. general electric type: CLT one square D transformer cat#15S1H type: S style: 12751-21612-005 dry type confirmed by research and one dry type cutler hammertransformer	19 20 21 22	Reactor - part of 4160 old system.
5/200	both transformers are dry type cutler hammer transformers. Dry type confirmed by sticker.	23 24 25 26	
5/300	acme dry type transformer cat#TP1-53347-3S style: G UL listing: 5428 dry type confirmed by research	27 28 29	Electrical room.
20/200		30 31	New transformer.
18/200	one federal pacific dry type transformer cat#T4T112E two cutler hammer dry type transformers one federal pacific dry type main distrabution center(main electrical distrubution). Dry type confirmed by sticker.	32 33 34 35 36 37	transformers are located in the main elecrical room in the gallery bldg 18 the two cutler hammer transformers are new the federal pacific one is old the main distrabution center is old and a 4160 volt main power sorce for the brewery
15/200	federal pacific cat#WS-12 model: 36B. Dry type confirmed by sticker.	38 39	this is a required stand by transformer
street side	kuhlman transformer. Property of Seattle City Light. square D cat#75T3H type: SO UL listing 127H dry type confirmed by research	40 41	Farallon report)2004) confirmed with City Lights that this transformer is oil type but is non PCB. located in the lower portion of the compound facing the street
10/100	international transformer corporation cat#100S83H-C type:HSUL UL listing:834K	42 43	in the lower portion of the compound facing the street raised above head level on the wall
11/100		44 45	

catalog information can be confirmed at <http://ecatalog.squared.com/>